



Bruhat Bengaluru  
Mahanagara Palike

Office of the Executive Engineer [Town Planning]  
III Floor, Annexe Building No.2, N R Road,  
BANGALORE-560 002

Ref No: EETP/BBMP/774/VGS/2024-25

2<sup>nd</sup> August 2024

### BUILDING SAFETY CERTIFICATE

This is to herewith certify that the Building Constructed by the Certified Structural Engineer of the Bruhat Bengaluru Mahanagara Palike, was inspected by the undersigned on 2<sup>nd</sup> August 2024 & the same was assessed based on Visual Inspection, Building Safety Test and Approved Building Plans.

1. ADDRESS OF THE BUILDING: **Vels Global School,  
No.3/7, Arakere, Bannerghatta Road,  
BANGALORE-560 076**
1. The existing school Building comprises of Partial Basement, Ground Floor [GF] + 3 Upper Floors with RCC Roof Construction.
2. Building, having constructed, in Phased manner with RCC Columns and Beams-RCC Framed Structure with 9" thick walls in between all the blocks, North, South, East and West sides are in good conditions with good ventilation and Spacious Class Rooms [26'0" x 26' x 20'] with 7'6" Wide Corridors, Spacious Laboratory, Staircases at 2 Locations and with Sufficient Toilet and Rest Rooms.
3. The foundation for the structure is rested on Hard Soil, with Safe Bearing Capacity [S.B.C.] of Soil around 21 T /Sq.mt & the building is designed for Basement, GF + 3 Upper floors designed compliance to School Purpose. The Slabs and Beams are designed as one way/two way slabs with Beams & Columns as per design drawings & also all the Class Rooms are able to accommodate around 40 Students.
4. The School has also complied to all Fire and Emergency Services Department Compliances by adhering to provision of Fire Safety Equipments and has the NOC from the Fire and Emergency Services Dept, Govt of Karnataka

ls





5. Based on visual inspection, it was found that all Beams / Column sizes are as per drawings and no cracks were observed; hence the building is safe enough for the Serviceability Criterion.
6. All the rooms are well ventilated and the electrical Lighting Points are adequately fixed for obtainment of good intensive light. All the Electrical control Switches and Sockets are above reasonable height [6'6"], to ensure safety of the children. Individual rooms have the Miniature Circuit Breakers to take care of Short Circuits. The Electrical Ducts are laid as per norms of BESCOM which are observed to not to affect the safety of the Building.
7. The Drainage pipes are laid as per the norms of BWSSB from the Rest Rooms and are observed that it will not be a hindrance to the safety norms of the building.
8. The Water supply pipes and Over Head Water Storage tank also is observed to be positioned as per the Norms of the Building Safety and all the water ducts are laid as per the norms of BWSSB.
9. All corridors are covered with RCC Mesh wall and MS Hand Rails up to 6'0" height to ensure the safety of the children. The foundation has a framed structure with columns and beams, adequate foundation has been adopted for the structure, and Ground floor P.T.Slab roof has been casted. All other structural elements have been executed as per IS Standards with adequate finishing and till date building has been maintained very well. We have not observed any cracks, swelling, sagging in any part of the structure.

We hereby certify that the structure is safe enough to take the loads on the structure. The structure is sound and stable to serve for the rest of its life.

✓  
ll



*[Signature]* 21/8/24  
Executive Engineer [Town Planning]  
Bruhat Bengaluru Mahanagara Palike  
Building Annexe 2, N R Road,  
BANGALORE-560 002