



Karnataka Fire and Emergency Services
Sarjapura Fire Station, Bangalore East Zone
BANGALORE-560 035,
Phone: 080 - 25746166



No. 114/ DFO[E] / SRF5 / BNG /VGS/2024-25

Date: 02-08-2024

To,

The Chairman,
Vels Global School,
Site No.29/1, Somasundara Palya,
Sector 2, HSR Layout
BANGALORE-560 102

Sir,

Sub: Issual of '**Fire Safety Certificate**' to Vels Global School, Site No.29/1,
Somasundara Palya, Sector 2, HSR Layout BANGALORE-560 102

Ref: Your Letter dated 01-08-2024

* * *

With reference to the subject above cited, the premises **Vels Global School, Site No.29/1, Somasundara Palya, Sector 2, HSR Layout, BANGALORE-560 102** was inspected by District Fire Officer, Sarjapur Road Fire Office, Bengaluru on 02-08-2024 with respect to Fire Prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under;

ANNEXURE-B

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub division B1 & B2
(These conditions are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the building / premises:-

- 01 Name and Address of the Applicant : **The Chairman,
Vels Global School,
Site No.29/1, Somasundara Palya,
Sector 2, HSR Layout
BANGALORE-560 102**
02. Name and Address of the Premises : **The Chairman,
Vels Global School,
Site No.29/1, Somasundara Palya,
Sector 2, HSR Lay Out
BANGALORE-560 102**

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety Point of view:-

SL NO (1)	Details (2)	Existing (3)	Recommendations (4)
01.	Accessibility to the Premises	The premises is accessible from 09.00 mtr wide Road	Adequate

1

PRINCIPAL
VELS GLOBAL SCHOOL
29/1, Somasundara Palya, Near Sobha Dargudi
Sector 2, PWD Quarters, 1st Sector, HSR Layout
Bangalore - 560 102

02. Number of Entrances	01 Entrance/s with 4.8 mtr wide from 9.0 mtr Wide Road	Adequate
03. Number of Stair Cases	Adequate Staircases. All of 01.5 mtr width	Adequate
04. Open Space Available	East 2.0 mtr West 4.0 mtr North 2.3 mtr South 0.8 mtr	Adequate
05. Portable extinguishers	13 Nos of ABC type fire extinguishers Each of 02 kgs. 6kg capacity & 02 Nos of 4.5 kgs Capacity & 3 fire buckets filled with clean dry Sand & water have been extinguisher of 6 kgs should provided	In-additional to the existing fire extinguishers although adequate A. One ABC type be provided at each floor B. One Water mist Extinguisher of 9 ltr capacity Should be kept near each Staircase landing C. One Mechanical Foam Extinguisher of 9 ltr capacity & one ABC type of Ext of 6kgs capacity should be Provided
03. Escape Routes	Displayed	Escape routes are indicated in the corridor on each floor
04. Fire Safety Plans	Displayed	A Notice Board is indicative every floor with options to be displayed by staff with Telephone Numbers of Sarjapura Fire Station
05. Fire Fighting Training	Imparted to 25% staff	At least 40% of the staff Should get trained in Basic fire fighting at R A Mundkur Fire and Emergency Services Academy, Bannerughatta Road, Bangalore

Ramesh

Parvathy Venugopal

PRINCIPAL
VELS GLOBAL SCHOOL
29/1, Samasandra Palya, Near Sobha Daffar
Sector 2, FWD Quarters, 1st Sector, HSF
Bangalore - 560 102

06. Fire Precautionary Measures:-

- A. Explosive and inflammable materials should not be stored in the store room UPS Room, Electrical Panel Area, Class Rooms, Laboratory & Electrical Panel Premises
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction
- D. Liquefied Petroleum Gas should not be stored in the building
- E. Doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside or outside/
- G. As per Hon'ble Supreme court orders all teachers and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing **'FIRE SAFETY CERTIFICATE'** to Vels Global School, Site No.29/1, Somasundara Palya, Sector 2, HSR Layout BANGALORE-560 102


This **'FIRE SAFETY CERTIFICATE'** is issued for a period of **ONE YEAR** from the date of issue & is renewable.

❖ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life Safety will have to complied with, mandatorily

3 Pages only



Yours faithfully,


District Fire Officer
Sarjapura Road Fire Station
BANGALORE-560 035



PRINCIPAL
VELS GLOBAL SCHOOL
29/1, Samasandra Palya, Near Sobha
Sector 2, FWD Quarters, 1st Sector, HSR
Bangalore - 560 102