



Karnataka Fire and Emergency Services  
Banashankari Fire Station, Bangalore South Zone  
Banashankar 2<sup>nd</sup> Stage, BANGALORE-560 070  
Phone: 080 – 22971529

No. DFO[S] / 7761 / VGS / 2024-25

Date: 02-08-2024

To,

The Chairman,  
Vels Global School,  
No.3/7, Arakere, Bannerghatta Road,  
BANGALORE-560 076

Sir,

Sub: Issual of '**Fire Safety Certificate**' to Vels Global School, No.3/7, Arakere,  
Bannerghatta Road, BANGALORE-560 076

Ref: Your Letter dated 01-08-2024

\* \* \*

With reference to the subject above cited, the premises **Vels Global School, No.3/7, Arakere, Bannerghatta Road, BANGALORE-560 076** was inspected by District Fire Officer, South Zone, Bengaluru on 02-08-2024 with respect to Fire Prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under;

**ANNEXURE-B**

*NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub division B1 & B2*  
( These conditions are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

**A. Details of the building / premises:-**

01. Name and Address of the Applicant : **The Chairman,  
Vels Global School,  
No.3/7, Arakere, Bannerghatta Road,  
BANGALORE-560 076**
02. Name and Address of the Premises : **The Chairman,  
Vels Global School,  
No.3/7, Arakere, Bannerghatta Road,  
BANGALORE-560 076**
03. Number of Buildings : **One building with 01 wings**
04. Number of Floors : **Ground & 2 upper floors**
05. Floor-wise details of occupancy : **Ground floor : Reception, Admin & Accounts Room,  
Chairman Room, Principal Room, Information Room,  
AV Room, Stores, Day Care, Infirmary Room, CHAMPS  
Room, 5 Class Rooms, 2 Sports Rooms, Store Room, Toy  
Room.  
First Floor : Staff Room, Math Lab, Composite  
Science Lab, Computer Lab, 5 Class rooms,**

✓  
Checked

Second Floor: Library, 3 Class Rooms

Third Floor: Computer Lab, Physics Lab, Chemistry Lab and Biology Lab, STEM lab with 5 Class Rooms

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety Point of view:-

SL NO (1)	Details (2)	Existing (3)	Recommendations (4)
01.	Accessibility to the Premises	The premises is accessible from 09.00 mtr wide Road	Adequate
02.	Number of Entrances	01 Entrance/s with 4.9 mtr wide from 9.0 mtr Wide Road.	Adequate
03.	Number of Stair Cases	06 Staircases, All of 01.5 mtr width	Adequate
04.	Open Space Available	East : 2.0 mtr West: 4.0 mtr North: 2.3 mtr South: 0.9 mtr	Adequate
05.	Portable extinguishers	13 Nos of ABC type fire extinguishers Each of 02 kgs, 6kg capacity & 02 Nos of 4.5 kgs Capacity & 3 fire buckets filled with clean dry Sand & water have been extinguisher of 6 kgs should provided	<b>In-additional to the existing fire extinguishers</b> <b>although adequate</b> A. One ABC type be provided at each floor B. One Water mist Extinguisher of 9 ltr capacity Should be kept near each Staircase landing C. One Mechanical Foam Extinguisher of 9 ltr capacity & one ABC type of Ext of 6kgs capacity should be Provided
06.	Escape Routes	Displayed	Escape routes are indicated In the corridor on each floor
07.	Fire Safety Plans	Displayed	A Notice Board is Indicative every floor with Options to be deployed by

✓ Checked

08. Fire Fighting Training

Imparted to 25% staff

At least 40% of the staff  
Should get trained in  
Basic fire fighting at  
R A Mundkur Fire and  
Emergency Services  
Academy, Bannerughatta  
Road, Bangalore

09. Fire Precautionary Measures:-

- A. Explosive and inflammable materials should not be stored in the store room UPS Room, Electrical Panel Area, Class Rooms, Laboratory & Electrical Panel Premises
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction
- D. Liquefied Petroleum Gas should not be stored in the building
- E. Doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside or outside/
- G. As per Hon'ble Supreme court orders all teachers and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing '**FIRE SAFETY CERTIFICATE**' to Vels Global School, No.3/7, Arakere, Bannerghatta Road, BANGALORE-560 076 This '**FIRE SAFETY CERTIFICATE**' is issued for a period of ONE YEAR from the date of issue & is renewable.

❖ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life Safety will have to complied with, mandatorily

3 Pages only



Yours faithfully,

District Fire Officer [South]  
BANGALORE-560 070