

# TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT

## NO OBJECTION CERTIFICATE

LICENSE NO: 70/V/2025  
R.C.NO : 405/V/2025  
DATE : 27.06.2025


Virugambakkam Fire and Rescue  
Service Station

Subject: Fire and rescue service department – Virugambakkam Fire and Rescue Service Station for purpose of no objection certificate – REG.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004  
(2) G.O. No.123 School Edu( 2 ) Dept, Date : 14.09.2004  
(3) Date of Requisition letter from The Principal,  
VELS GLOBAL SCHOOL Date – 24.06.2025

Based on the Govt. order mentioned above and the requisition letter given by the VELS GLOBAL SCHOOL at No:137, LOTUS VILLA, VASANTHAM NAGAR, NANDAMBAKKAM, CHENNAI-600089. Tamil Nadu the building and premises comprises of G+1 Floor owned/occupied VELS GLOBAL SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 26.06.2025 in the presence of Principal and that the school is granted NOC for a period of one year from subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY FIRE & RESCUE SERVICES , STATION OFFICER , M.ELANGO VAN ON 26.06. 2025



*M. Elango Van*  
26/06/25  
STATION OFFICER  
FIRE AND RESCUE STATION  
VIRUGAMBAKKAM, CHENNAI - 600 089,

To:

THE PRINCIPAL,  
VELS GLOBAL SCHOOL  
No:137, LOTUS VILLA, VASANTHAM NAGAR,  
NANDAMBAKKAM, CHENNAI-600089.

CC : District Officer, Central Chennai District

*Indira*  
PRINCIPAL  
VELS GLOBAL SCHOOL  
No: 137 / 1, LOTUS VILLA  
VASANTHAM NAGAR,  
NANDAMBAKKAM, CHENNAI-600 089.

## CONDITIONS

1. This License is valid for **ONE YEAR** from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
  - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
  - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
  - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
  - d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
  - e) Mock drill has to be conducted at regular intervals in consultation with the Divisional Officer, Fire and Rescue Services, Chennai City Central Division at Kilpauk.
  - f) The classrooms should always be in the ground floor up to 3<sup>rd</sup> standards.
  - g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
  - h) The classroom doors/ windows shall always open outwards.
  - i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
  - j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
  - k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.

*Handwritten signature*

**PRINCIPAL**  
**ELS GLOBAL SCHOOL**  
No: 137 / 1, LOTUS VILLA  
VASANTHAM NAGAR,  
MADAMBAKKAM, CHENNAI-600 089.

*Handwritten signature*  
STATION OFFICER 24/06/25  
FIRE AND RESCUE STATION  
VIRUGAMBAKKAM, CHENNAI - 600 089,