

**CERTIFICATE OF STRUCTURAL SOUNDNESS  
VELS GLOBAL SCHOOL  
MEDAVAKKAM -BLOCK A  
DUPLICATE COPY**

**CERTIFICATE OF STRUCTURAL SOUNDNESS**

**VELS GLOBAL SCHOOL  
BLOCK -A**

**No 10/421,422,MAMBAKKAM MAIN ROAD,**

**MEDAVAKKAM VILLAGE,**

**CHENNAI -600100.**

**FURNISHED BY**

**V.RAMACHANDRAN M.E (STRUCTURAL ENGINEERING),**

**SUPERINTENDING ENGINEER PWD (RETD),**

**PANEL ENGINEER, CHENGALPATTU DISTRICT,**

**CLASS 1A**

**NO 1029/2020/M 1/ DT 14-07-2021**

*J. Christina Juliet*

**Principal**

**VELS GLOBAL SCHOOL**

**No: 10 / 421, 422, Mambakkam Main Road,**

**Medavakkam, Chennai-600 100.**

FORM OF APPLICATION UNDER SUB SECTION (1), SUBSECTION (2), OF SECTION 4 OF THE  
TAMILNADU PUBLIC BUILDINGS ACT (LICENSING) 1965 (TAMILNADU ACT 13 OF 1965)  
REFERRED TO RULE 3 OF TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966.

FROM:

The Principal,  
VELS GLOBAL SCHOOL  
No 10/421,422,MAMBAKKAM MAIN ROAD,  
MEDAVAKKAM VILLAGE,  
Chennai -600100.

TO: The Competent Authority,  
Chengalpattu District,  
Chengalpattu

- 1 I intend to use the building/ to continue to use the existing public building A Block as a public Building which is situated in the Door No 10/421,422 Mambakkam Main Road, Medavakkam village, Chennai -600100 S.NO 427/200A, 427/200B, for the period from 01-06-2025 to 31-05-2028 (three years)
2. The Year of construction and the present approximate construction cost and purpose for which it is to be used or being used as public building are also furnished in the statement accompanying this application.
3. I enclose a challan for Rs
4. I also enclose a certificate of structural soundness in the prescribed form furnished by the Engineer Mr.V.Ramachandran


Dated:

Signature of the owner of the building

Enclosures:

1. Statement
2. Challan for Rs

towards the application

  
Principal

**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.



## STATEMENT ACCOMPANYING FORM - A

1. Name of the building : VELS GLOBAL SCHOOL
2. Location/ Street No, Name of place : No 10/421,422, Mambakkam MainRoad  
Medavakkam village  
Chennai-600100, S.NO 427/200A,427/200B
3. Year of construction : 2013 B BLOCK
- Area details
- |                           |                       |                     |
|---------------------------|-----------------------|---------------------|
| a) Ground floor (RCCROOF) | : plinth area (Sq ft) | carpet area (Sq ft) |
| b) First floor (RCCROOF)  | 7484                  | 6361                |
| c) Second floor (RCCROOF) | 7484                  | 6361                |
| d) Terrace (Head room)    | 7484                  | 6361                |
|                           | 855                   | 726                 |
|                           | 23305                 | 19809               |
- 4) Approximate cost of construction at current rates : Rs583 lakhs
- 5) Purpose for which building is used : School Building
- 6) Purpose for which building has hitherto been used : School Building
- 7) Details of construction of the building (particulars of the foundation, soil specification of various parts under)
- a) foundation : isolated column foundation, with plinth beam
- b) basement/ superstructure : brick work in cement mortar, in masonry works
- c) superstructure, floor and roof : brick work in cement mortar, RCC BEAM  
RCC roof, tiles flooring etc

*J. Christina Jubet*

Principal

**VELS GLOBAL SCHOOL**

No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

8) Period for which the license is required : 01-06-2025 to 31-05-2028 (Three years)  
9) Number of persons to be accommodated : 1300 Students


SIGNATURE OF OWNER OF BUILDING

: SIGNATURE OF ENGINEER

DESIGNATION   
V. RAMACHANDRAN  
B.E.(Civil), M.E. (Structural Engg.), FIV  
Superintending Engineer FWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No: 7 / 8, Mougambigai Street,  
Jai Balaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile: 9486501083

Certified that no thatched roof buildings are used for conducting classes in school premises. If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that I /We are aware that our license will be cancelled

SIGNATURE OF THE OWNER OF THE BUILDING

  
Principal

**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

**V. RAMACHANDRAN**

B.E., (Civil), M.E., (Structures), M.Sc., (REV), F.I.V  
Govt. Registered Valuer  
Registered Panel Engineer Class IA  
Chennai, Kancheepuram, Thiruvallur &  
Chengalpattu Districts.

Superintending Engineer PWD (Retd.)  
Govt. of Tamilnadu  
No.7/8, Moogambigai Street, Jai Balaji Nagar,  
Nesapakkam, Chennai - 600 078.  
Cell : 94865 01083.  
E-mail : r.chandran47@rediffmail.com


FORM -B

03-06-2025


Date: .....  
**FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4)  
OF SECTION 4 OF THE TAMILNADU PUBLICBUILDING (LICENSING) ACT1965  
(TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU  
PUBLIC BUILDINGS (LICENSING) RULES 1966**

**CERTIFICATE OF STRUCTURAL SOUNDNESS**

I certify that I have inspected the school building named VELS GLOBAL SCHOOL, No 10/421,422, B BLOCK, Mambakkam Main Road, Medavakkam village, Chennai -600100, Survey No 427/200A &427/200B on 02-06-2025. I have satisfied myself that the building structurally sound to be used as a public building for the purpose noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS:875. The scope of this stability certificate is limited only to the structural soundness of the building as per IS: 456-2000.This does not include the eventualities caused by natural calamities like cyclone, earthquake, high gales & storms, lightening, floods, fire etc. A license may be granted for the period from 01-06-2025 to 31- 05-2028 (Three Years). Certified that no thatched buildings are there for conducting classes in the school premises as on date of inspection.

  
V. RAMACHANDRAN  
B.E. (Signature of Engineer), F.I.V  
Superintending Engineer PWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No.7/8, Moogambigai Street,  
Nesapakkam,  
Chennai - 600 078.  
Cell : 94865 01083

A copy of approved plan and lease agreement is produced during inspection. This certificate is based on physical inspection and actual measurements

  
Principal  
**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

## FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4) OF SECTION 4 OF THE  
TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 13 OF 1965) REFERRED TO IN  
RULE 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

- i) Depth below ground level : 6 ft
- ii) Nature of soil met in the foundation level : Clay with fine sand mix.
- iii) Pressure at foundation : within allowable limits.
- iv) Probable safe bearing capacity of the strata met : 15 .00tonnes/Sq m  
with at foundation


2. Superstructure


- i) Maximum stress in the most critical section of : Masonry 0.75 Kg/ sq.cm  
masonry and concrete : Concrete 35 Kg/sq cm
- ii) Nature of masonry and concrete and it's safe : Masonry 5 Kg / sq cm  
permissible stress : Concrete 70 Kg/sq cm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-06-2025 to 31-05-2028 (Three Years)

Place: Chennai

Date: 02-06-2025

  
**V. RAMACHANDRAN**  
B.E.(Civil), M.E.(Structural Engg.), FIV  
Superintending Engineer FWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No. 7/8, Mougambigai Street,  
Jambhavanagar, Nesapakkam,  
Chennai - 600 078.  
Mobile No: 98401083

  
Principal


**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.


**STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

Location of the building, door no, street name, & name of the place  (1)	Age of building  (2)	Value of the building  (3)	no of storey  (4)	Short description RCC framed, or load bearing masonry  (5)
VELS GLOBAL SCHOOL B BLOCK, No, 10/421.422,Mambakkam Main Road,Medavakkam village Chennai- 600100.	12 years	Rs 355 lakhs	G+2	Framed structure, column foundation, brick walls, RCC Beams, RCC Roof, tiles flooring etc

Purpose for which the building is certified for use  (6)	The period for which the building will be structurally sound  (7)	No of persons to be accommodated  (8)	Remarks
school building	01-06-2025 to 31-05-2028 (Three years)	1300 students	Building is structurally sound.

SIGNATURE OF THE ENGINEER

  
**V. RAMACHANDRAN**  
 B.E.(Civil).M.E.(Structural Engg.),FIV  
 Superintending Engineer FWD (Retd)  
 Government Registered  
 Panel Engineer, Class - 1A,  
 Chennai & Kancheepuram District  
 No: 77 b, Mougambigai Street,  
 Jal Bahi Nagar, Nesapakkam,  
 Chennai - 600 078.  
 Mobile: 9488501083

  
**J. Christina Jubet**

Principal

**VELS GLOBAL SCHOOL**  
 No: 10 / 421, 422, Mambakkam Main Road,  
 Medavakkam, Chennai-600 100.

**FORM - E**

FORM OF REPORT TO BE MADE TO THE COMPETENT AUTHORITY BY THE INSPECTING AUTHORITIES OR OFFICERS APPOINTED UNDER OTHER ACT UNDER SECTION 28 OF TAMILNADU PUBLIC BUILDINGS LICENSING ACT 1965 (TAMILNADU ACT 13 OF 1965) REFERRED TO RULE 7 OF TAMILNADU PUBLIC BUILDINGS LICENSING RULE 1966

1. Name and designation of inspecting Authority : V.RAMACHANDRAN  
or officer appointed or having jurisdiction under : B.E (CIVIL), M.E(STRUCTURALENGG)  
any other act or law : F.I.V  
: Superintending Engineer PWD(Retd)  
: Government Registered  
: Panel Engineer Class-1A  
: CHENGALPATTU DISTRICT  
: No,7/8 Moogambigai street,  
: Jai Balaji Nagar, Nesapakkam,  
: Chennai-600078,  
: Mobile no - 9486501083
2. Location of the building inspected : VELS GLOBAL SCHOOL  
D.NO. Street No, name of place : B BLOCK No 10/421,422, Mambakkam main Road  
i.e Municipal corporation/Municipality/ panchayat/ : Medavakkam village  
Panchayat union/ township/ cantonment : Chennai - 600100
3. Date of inspection : 02-06-2025
4. Purpose for which the building is used : School Purpose
5. Nature of defects noticed : Annex- 1
6. Suggestion for rectifying defect : During maintenance should be taken care
7. If in a dangerous condition immediate action : NIL  
Recommended to be taken.

*J. Christina Juliet*  
Principal

**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

*V. Ramachandran*  
03/06/2025  
V. RAMACHANDRAN  
B.E.(Civil),M.E.(Structural Engg.),FIV  
Superintending Engineer PWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Koncheepuram District  
No: 7 / 8, Moogambigai Street,  
Jai Balaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile: 9486501083

ANNEXURE -1


The following are the observations made during current inspection on 02-06-2025

Ground floor

1) In Boys toilet & Girls toilet dampness at bottom of the roof is seen This should be taken care

Terrace

2) At Headroom (new) in walls horizontal crack is noticed



V. RAMACHANDRAN  
B.E.(Civil),M.E.(Structural Engg.),FIV  
Superintending Engineer FWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No: 7 / 8, Mougambigai Street,  
Jai Balaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile: 9486501083



Principal  
**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

**CERTIFICATE OF STRUCTURAL SOUNDNESS  
VELS GLOBAL SCHOOL  
MEDAVAKKAM -BLOCK B  
DUPLICATE COPY**

**CERTIFICATE OF STRUCTURAL SOUNDNESS**

**VELS GLOBAL SCHOOL  
BLOCK -B**

**No 10/421,422,MAMBAKKAM MAIN ROAD,**

**MEDAVAKKAM VILLAGE,**

**CHENNAI -600100.**

**FURNISHED BY**

**V.RAMACHANDRAN M.E (STRUCTURAL ENGINEERING),**

**SUPERINTENDING ENGINEER PWD (RETD),**

**PANEL ENGINEER, CHENGALPATTU DISTRICT,**

**CLASS 1A**

**NO 1029/2020/M 1/ DT 14-07-2021**

*J. Christina Juliet*  
Principal

**VELS GLOBAL SCHOOL**

**No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.**

## STATEMENT ACCOMPANYING FORM - A

1. Name of the building : VELS GLOBAL SCHOOL
2. Location/ Street No, Name of place : No 10/421,422, Mambakkam Main Road  
Medavakkam village  
Chennai-600100, S.NO 427/200A,427/200B
3. Year of construction : 2013 A BLOCK
- | Area details              | plinth area (Sq ft) | carpet area (Sq ft) |
|---------------------------|---------------------|---------------------|
| a) Ground floor (RCCROOF) | 4622                | 3930                |
| b) First floor (RCCROOF)  | 4622                | 3930                |
| c) Second floor (RCCROOF) | 4622                | 3930                |
| d) Terrace (Head room)    | 343                 | 290                 |
|                           | 14209               | 12080               |
- 4) Approximate cost of construction at current rates : Rs 355 lakhs
- 5) Purpose for which building is used : School Building
- 6) Purpose for which building has hitherto been used : School Building
- 7) Details of construction of the building (particulars of the foundation, soil specification of various parts under)
- a) foundation : isolated column foundation, with plinth beam
- b) basement/ superstructure : brick work in cement mortar, in masonry works
- c) superstructure, floor and roof : brick work in cement mortar, RCC BEAM Column, RCC roof, tiles flooring etc

*J. Christmá Juliet*

Principal

**VELS GLOBAL SCHOOL**

No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

8) Period for which the license is required : 01-06-2025 to 31 -05-2028 (Three years)  
9) Number of persons to be accommodated : 800 Students


SIGNATURE OF OWNER OF BUILDING

: SIGNATURE OF ENGINEER

DESIGNATION  
V. RAMACHANDRAN  
B.E.(Civil),M.E.(Structural Engg.),FIV  
Superintending Engineer FWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No: 7 / 6, Mougamaigal Street,  
Jai Batsji Nagar, Nandanam,  
Chennai - 600 079.  
Mobile: 9486601093

Certified that no thatched roof buildings are used for conducting classes in school premises. If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that I /We are aware that our license will be cancelled

SIGNATURE OF THE OWNER OF THE BUILDING



Principal  
**VELS GLOBAL SCHOOL**  
No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

**V. RAMACHANDRAN**

B.E., (Civil), M.E., (Structures), M.Sc., (REV), F.I.V  
Govt. Registered Valuer  
Registered Panel Engineer Class IA  
Chennai, Kancheepuram, Thiruvallur &  
Chengalpattu Districts.

Superintending Engineer PWD (Retd.)  
Govt. of Tamilnadu  
No.7/8, Moogambigai Street, Jai Balaji Nagar,  
Nesapakkam, Chennai - 600 078.  
Cell : 94865 01083.  
E-mail : r.chandran47@rediffmail.com

**FORM -B**


**03-06-2025**

Date : .....

**FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4)  
OF SECTION 4 OF THE TAMILNADU PUBLICBUILDING (LICENSING) ACT  
1965(TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE  
TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966**

**CERTIFICATE OF STRUCTURAL SOUNDNESS**

I certify that I have inspected the school building named VELS GLOBAL SCHOOL, No 10/421,422, A BLOCK, Mambakkam Main Road, Medavakkam village, Chennai -600100, Survey No 427/200A & 427/200B on 02-06-2025. I have satisfied myself that the building structurally sound to be used as a public building for the purpose noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS:875. The scope of this stability certificate is limited only to the structural soundness of the building as per IS :456-2000. This does not include the eventualities caused by natural calamities like cyclone, earthquake, high gales & storms, lightening, floods, fire etc. A license may be granted for the period from 01-06-2025 to 31-05-2028 (Three Years). Certified that no thatched buildings are there for conducting classes in the school premises as on date of inspection.



Signature of Engineer

V. RAMACHANDRAN  
B.E.(Civil),M.E.(Structural Engg.),FIV  
Superintending Engineer PWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No:7 / 8, Moogambigai Street,  
Jai Balaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile : 94865 01083



Principal

**VELS GLOBAL SCHOOL**  
No: 10/ 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

## FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

### 1. Foundation

- i) Depth below ground level : 6 ft
- ii) Nature of soil met in the foundation level : Clay with fine sand mix.
- iii) Pressure at foundation : within allowable limits.
- iv) Probable safe bearing capacity of the strata met : 15.00 tonnes/Sq m  
with at foundation


### 2. Superstructure


- i) Maximum stress in the most critical section of masonry and concrete : Masonry 0.75 Kg/ sq.cm  
: Concrete 35 Kg/sq cm
- ii) Nature of masonry and concrete and it's safe permissible stress : Masonry 5 Kg / sq cm  
: Concrete 70 Kg/sq cm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-06-2025 to 31-05-2028 (Three Years)

Place: Chennai

Date: 03-06-2025


  
V. RAMACHANDRAN  
B.E.(Civil), M.E.(Structural Engg.), FIV  
Superintending Engineer FWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No: 778, Mougaraigal Street,  
Jai Balaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile: 9486501093


  
Principal  
**VELS GLOBAL SCHOOL**  
No: 10/421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, door no, street name, & name of the place (1)	Age of building (2)	Value of the building (3)	no of storey (4)	Short description RCC framed, or load bearing masonry (5)
VELS GLOBAL SCHOOL, A BlockNo,10/421.422 Mambakkam Main Road,Medavakkam village Chennai-600100.	12 years	Rs 355 lakhs	G+2	Framed structure, column foundation, brick walls, RCC Beams, RCC Roof, tiles flooring etc

Purpose for which the building is certified for use (6)	The period for which the building will be structurally sound (7)	No of persons to be accommodated (8)	Remarks
school building	01-06-2025 to 31-05-2028 (Three years)	800 students	Building is structurally sound.

  
 SIGNATURE OF THE ENGINEER  
**V. RAMACHANDRAN**  
 B.E.(Civil),M.E.(Structural Engg.),FIV  
 Superintending Engineer FWD (Retd)  
 Government Registered  
 Panel Engineer, Class - 1A,  
 Chennai & Ranichespuram District  
 No: 7/8, Mox parnaigai Street,  
 Jai Balaji Nagar, Nesapakkam,  
 Chennai - 600 073  
 Mobile: 9448-11-6013

  
**Principal**  
**VELS GLOBAL SCHOOL**  
 No: 10 / 421, 422, Mambakkam Main Road,  
 Medavakkam, Chennai-600 100.

**FORM - E**

FORM OF REPORT TO BE MADE TO THE COMPETENT AUTHORITY BY THE INSPECTING AUTHORITIES OR OFFICERS APPOINTED UNDER OTHER ACT UNDER SECTION 28 OF TAMILNADU PUBLICBUILDINGS LICENSING ACT 1965 (TAMILNADU ACT13 OF 1965) REFERRED TO RULE 7 OF TAMILNADU PUBLIC BUILDINGS LICENSING RULE 1966.

1. Name and designation of inspecting Authority : V.RAMACHANDRAN  
or officer appointed or having jurisdiction under : B.E (CIVIL), M.E(STRUCTURALENGG)  
any other act or law : F.I.V  
: Superintending Engineer PWD(Retd)  
: Government Registered  
: Panel Engineer Class-1A  
: CHENGALPATTU DISTRICT  
: No 7/8 Moogambigai street,  
: Jai Balaji Nagar, Nesapakkam,  
: Chennai-600078,  
: Mobile no - 9486501083
2. Location of the building inspected : VELS GLOBAL SCHOOL  
D.NO. Street No, name of place : A BLOCK, No 10/421,422, Mambakkam main Road  
i.e Municipal corporation/Municipality/ panchayat/ : Medavakkam village  
Panchayat union/ township/ cantonment : Chennai - 600100
3. Date of inspection : 02-06-2025
4. Purpose for which the building is used : School Purpose
5. Nature of defects noticed : Annex -1
6. Suggestion for rectifying defect : During maintenance should be taken care
7. If in a dangerous condition immediate action : NIL  
Recommended to be taken.

*J. Christina Jubet*  
Principal

**VELS GLOBAL SCHOOL**  
No: 10/421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.

*V. Ramachandran*  
V. RAMACHANDRAN  
B.E.(Civil), M.E.(Structural Engg.), FIV  
Superintending Engineer PWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A  
Chennai & Kancheepuram District  
No: 7 / 8, Moogambigai Street,  
Jai Balaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile: 9486501083

ANNEXURE -1

The following are the observation made during current inspection on 02-06-2025


First floor

1) In south end wall at roof level Dampness at bottom of the roof is seen above window. This should be taken care


Second floor

2) At Girls toilet minor crack is noticed at roof bottom.

3) At room grade ix B and room grade viii B lintel level crack is noticed at the bottom of roof and wall



V. RAMACHANDRAN  
B.E.(Civil),M.E.(Structural Engg.),FIY  
Superintending Engineer FWD (Retd)  
Government Registered  
Panel Engineer, Class - 1A,  
Chennai & Kancheepuram District  
No: 7 / 8, Mougambigai Street,  
Jai Dattaji Nagar, Nesapakkam,  
Chennai - 600 078.  
Mobile: 9186501093



Principal

**VELS GLOBAL SCHOOL**

No: 10 / 421, 422, Mambakkam Main Road,  
Medavakkam, Chennai-600 100.