Annexure C

PRORORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 644H1/2026/H1 **Dated: 23.09.2026**

It is certified that an inspection team headed by **E. LAKSHMI GANESAN** From PUBLIC HEALTH DEPARTMENT **ZONE II DIVISION** inspected the **VELS GLOBAL SCHOOL #41/B, MEDAVAKKAM MAIN ROAD, KEELKATTALAI, CHENNAI – 117** on **22nd Sep. 2026** and found that **VELS GLOBAL SCHOOL # 41/B MEDAVAKKAM MAIN ROAD, KEELKATTALAI, CHENNAI – 600 117** has safe drinking water facilities for the students and members of staff of the institution School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The Certificate is valid for a period of one year from **6th Jan. 2026 to 05th Jan. 2027.**

Signature with Seal: 23/09/26

Name : **E. LAKSHMI GANESAN**

Designation : Sanitary Officer 1/C

Name & Address of the office/Department: Tambaram Municipal Corporation.

TAMBARAM CITY MUNICIPAL CORPORATION ★ PALLAVARAM ★

To,

VELS GLOBAL SCHOOL
 # 41/B MEDAVAKKAM MAIN ROAD
KEELKATTALAI CHENNAI-600117

- **The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.**

Tambaram City Municipal Corporation

SANITARY CERTIFICATE

Roc.No.5297/2026/H1 Dated: 06.01.2026

Certified that **VELS GLOBAL SCHOOL, NO.41B, MEDAVAKKAM MAIN ROAD, OPP. TO MAHATA PETROLEUM, KEELKATTALAI, CHENNAI – 600117** has been inspected by the Sanitary Inspector and the Building and premises are found satisfactory on the following aspects.

1. The ventilation & Lighting Facilities are Satisfactory.
2. The building is maintained properly.
3. The room and surroundings are maintained neat and clean.
4. The sanitary arrangements provided are adequate and satisfactory.
5. The supply of drinking water is wholesome.

The Sanitary certificate may be issued subject to the following conditions:

- The garbage generated within the building premises should be collected and disposed of properly by appointing required sanitary staff.
- On no account the garbage should be burnt.
- This certificate issued is liable to be cancelled at any time on infringement of any of the above set conditions and for improper maintenance of sanitation, improper maintenance of the building as well as urinals and toilets in the buildings.
- Adequate fire safety precautions should be made.
- Safe and protected drinking water alone should be supplied
- The premises should be inspected periodically for mosquito breeding places and all control measures should be taken to keep the premises mosquito free.
- For running a food establishment / canteen, permission should be obtained from the food safety department.
- incinerator shall be installed for safe disposal of sanitary napkins.
- The lab in charge should be well trained in handling the fire extinguisher.
- No smoking board should be displayed at predominent places with in the premises.
- No account sale of tobacco products should be permitted within the premises.
- Any occurrence of communicable disease should be notified to the Public Health Department.
- One time use and throw plastic is banned strictly by the Tamil Nadu Government. So ensure "Plastic Free" in your premises.
- Issued on 06.01.2026 Valid upto 05.01.2027 valid for One year only

TAMBARAM CITY MUNICIPAL CORPORATION * PALLAVARAM *

Sanitary Officer 06/01/2026
Tambaram City Municipal Corporation

6/1/26

Digitally signed by PantaSign Sub CA for DSC 2022
Date: 2026.10.09 17:36:47 +05:30
Reason: reason
Location: location

STATE LEVEL WATER TESTING LABORATORY
TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
NO 31, 4th FLOOR, TWAD HOUSE, KAMARAJAR SALAI,
CHEPAUK, CHENNAI – 600005.
Phone: 044 - 28412098 E-mail: twadboardcwa2024@gmail.com
TC-15754

TEST REPORT Doc. No.: SLWTL/FORM/7.8/01

Report No.	TR/2026/410-01	Report Issue Date	29.09.2026	Page No. : 01 of 01
Invoice Details	3876/dt.25.09.2026/Rs.1180/-	ULR. No.	TC 157542600000033F	

Client Name & Address Contact No. / Email.ID	:	VELS GLOBAL SCHOOL, No:41B, Medavakkam Main Road, Opp. to Mahata Petroleum, Keelkattalai, Chennai-600117.				
Sample Name	:	Water – Drinking Water				
Sample / Lab No.	:	2026/410				
Sample Source	:	Bore Well (RO)				
Sample Description	:	Clear Colorless Liquid				
Sample Submitted by	:	Customer				
Location & Date	:	In the School Premises(Keelkattalai)/dt.25.09.2026/01.00 PM				
Sample Container	:	Plastic – Good Condition				
Quantity of sample Received	:	2Litres	Sample Condition on Receipt	:	Good	
Sample Received on	:	25.09.2026	Environmental Condition	:	25.5°C	
Test Commenced on	:	25.09.2026	Test Completed on	:	29.09.2026	

S. No.	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Colour	IS 3025: Part 4: 2021	Hazen	BDL(DL=2)	5	15
2	Odour	IS 3025: Part 5: 2018	--	Agreeable	Agreeable	Agreeable
3	Taste	IS 3025: Part 8: 2023	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025: Part 10: 2023	NTU	BDL(DL=0.5)	1	5
5	pH @ 25°C	IS 3025: Part 11: 2022	--	**5.44**	6.5-8.5	No Relaxation
6	EC @ 25°C	IS 3025: Part 14: 2013	µS/cm	53	--	--
7	Total Dissolved Solids	IS 3025: Part 16: 2023	mg/L	35	500	2000
8	Total Alkalinity as $CaCO_3$	IS 3025: Part 23: 2023	mg/L	10	200	600
9	Total Hardness as $CaCO_3$	IS 3025: Part 21: 2009 (RA 2023)	mg/L	BDL(DL=5)	200	600
10	Calcium as Ca	IS 3025: Part 40: 2024	mg/L	BDL(DL=2)	75	200
11	Magnesium as Mg	IS 3025: Part 46: 2023	mg/L	BDL(DL=2)	30	100
12	Iron as Fe	IS 3025: Part 53: 2024	mg/L	BDL(DL=0.1)	1.0	No Relaxation
13	Chloride as Cl	IS 3025: Part 32: 2025	mg/L	8	250	1000
14	Nitrate as NO_3	IS 3025: (Part 34/Sec-1): 2023	mg/L	BDL(DL=2)	45	No Relaxation
15	Fluoride as F	IS 3025: (Part 60/Sec-1): 2023	mg/L	BDL(DL=0.2)	1.0	1.5
16	Sulphate as SO_4	IS 3025: (Part 24/Sec 1): 2022	mg/L	BDL(DL=5)	200	400

Remark: The tested sample does not conform to IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Chemical.

Note: 1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe).

29/9/26

Authorised Signatory
K. Rengaraj - Assistant Water Analyst

29/9/2026

Chief Water Analyst
TWAD Board, Chennai-5.

.....End of the Report.....

STATE LEVEL WATER TESTING LABORATORY
TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
NO 31, 4th FLOOR, TWAD HOUSE, KAMARAJAR SALAI,
CHEPAUK, CHENNAI – 600005.

Phone: 044 - 28412098 E-mail: twadboardcwa2024@gmail.com

TEST REPORT

Doc. No: SLWTL/FORM/7.8/01

Report No.	TR/2026/410-02	Report Issue Date	29.09.2026	Page No. : 01 of 01
Invoice Details	3876/dt.25.09.2026/Rs.1180/-	ULR. No.	--	

Client Name & Address Contact No. / Email.ID	:	VELS GLOBAL SCHOOL, No:41B, Medavakkam Main Road, Opp. to Mahata Petroleum, Keelkattalai, Chennai-600117.				
Sample Name	:	Water – Drinking Water				
Sample / Lab No.	:	2026/410				
Sample Source	:	Bore Well (RO)				
Sample Description	:	Clear Colorless Liquid				
Sample Submitted by	:	Customer				
Location & Date	:	In the School Premises(Keelkattalai)/dt.25.09.2026/01.00 PM				
Sample Container	:	Plastic – Good Condition				
Quantity of sample Received	:	2Litres	Sample Condition on Receipt	:	Good	
Sample Received on	:	25.09.2026	Environmental Condition	:	25.5°C	
Test Commenced on	:	25.09.2026	Test Completed on	:	29.09.2026	

S. No.	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	P. Alkalinity as $CaCO_3$	IS 3025: Part 23: 2023	mg/L	Zero	--	--
2	Sodium as Na	IS 3025 (Part 45) : 1993	mg/L	11	--	--
3	Potassium as K	IS 3025 (Part 45) : 1993	mg/L	BDL(DL=2)	--	--
4	Manganese as Mn	IS 3025 (Part 59) : 2023	mg/L	BDL(DL=0.05)	0.1	0.3
5	Ammonia as NH_3 - N	IS 3025 (Part 34) : 2019	mg/L	0.06	0.5	No relaxation
6	Nitrite as NO_2	IS 3025 (Part 34/Sec-1) : 2023	mg/L	BDL(DL=0.005)	--	--
7	Phosphate as PO_4	IS 3025 (Part 31/Sec-1) : 2022	mg/L	0.04	--	--
8	Oxygen Demand (Tidy's Test) 4 hrs. as O_2	IS 3025 (Part 63) : 2007	mg/L	0.08	--	--

Remark: The tested sample conform to IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Chemical.

Note: 1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. BDL: Below Detection Limit; DL: Detection Limit; NT: Not Tested (Bacteriologically unsafe).

29/9/26

Authorised Signatory
K. Rengaraj - Assistant Water Analyst

29/9/2026

Chief Water Analyst
TWAD Board, Chennai-5.

.....End of the Report.....